

0234

156

(AN ISO 9001 :2015 CERTIFIED LABORATORY)

TEST REPORT

Certificate No
TC-8433

Report /ULR No TC8433220000000234
 Sample Receipt Date 16.07.2025
 Analysis Date 16.07.2025 to 23.07.2025
 Date of Report Issue 24.05.2025
 Lab. Ref No / Date : PUREPO

Sample Code No AWQRC/07/25/234
 Sample Description Water
 Quantity 1 litre
 Sample Condition Satisfactory & Sealed
 Sample Type Water Sample
 Sample Detail Drinking Water(RO-2)

ISSUED TO:

BHARTIYA VIDYA BHAWAN
 (MEHTA VIDYALAYA) KG MARG
 NEW DELHI-110001

TEST RESULTS

PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
Sl.No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1	Turbidity	NTU	0.01	1	IS:3025 (Part 10)-1984
2	pH value		7.70	6.5-8.5	IS:3025 (Part 11)-1983
3	Total Dissolved Solids	mg/l	99	500	IS:3025 (Part 16)-1984
4	Total Hardness as CaCO ₃	mg/l	27	200	IS:3025 (Part 21)-2009
5	Calcium as Ca	mg/l	4.6	75	IS:3025 (Part 40)-1991
6	Magnesium as Mg	mg/l	2.6	30	IS:3025 (Part 46)-1994
7	Total Alkalinity as CaCO ₃	mg/l	12	200	IS:3025 (Part 23)-1986
8	Chloride as Cl	mg/l	16	250	IS:3025 (Part 32)-1988
9	Free Residual Chlorine	mg/l	0.2	0.2	IS:3025 (Part 26)-2021
10	Sulphate as SO ₄ "	mg/l	6.0	200	IS:3025 (Part 24)-1986

BUL= Below Detection Limit DL=Detection Limit.

Remarks:-

- 1) The Above water sample conforms to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted
- 2) The results relate to item tested.

Lab Address:

C-348, Floor, Ramphal Chowk
 Sector V, Dwarka, New Delhi
 Mob No: 9868911295, 01141608075
 Email: centralab@eurekaforbes.com

QUALITY MANAGER

Page 1 of 1

Corporate Office

E/12, 201, Marathon Innova, Off Ganpatrao Kadam Marg,
 Lower Parel, Mumbai - 400013, India

Regd. Office

7, Chakraberia Road (South)
 Kolkata-700025, India

DIMPLE JONEJA
 Principal

Bharatiya Vidya Bhavan's
MEHTA VIDYALAYA
 Kasturba Gandhi Marg, New Delhi

Scanned with OKEN Scanner