

e 65

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2024/ School/ 435

Dated: 17/05/2024

FIRE SAFETY CERTIFICATE

Certified that Bharatiya Vidya Bhawan located at Mehta Sadan, K.G. Marg, New Delhi comprises of 2 Basement + Ground + 04 upper floor (New blocks A, B & C & Old block) was earlier granted FSC by this department vide letter No. F6/DFS/MS/2021/school/331 dated 16/04/2021. Now, the premises was re-inspected by the officers concerned of this department on 08-05-2024 in the presence of Sh. Vijay Bhardwaj, Dy. Registrar and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-1 with effect from 17/05/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 17/05/2024 at New Delhi by.



(Atul Garg)
DIRECTOR
Delhi Fire Service


Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Sh. Vijay Bhardwaj (Dy. Registrar), Bharatiya Vidya Bhawan Complex at Mehta Sadan, K.G. Marg, New Delhi.

Condition for the validity of fire safety certificate

1. All the means of escape (passage way, corridor, staircase, etc.) shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Basement shall be used as per NBC/BDI, 1983.
6. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
7. This fire safety certificate may not be treated in any case for regularization of Unauthorized construction, if any.
8. The access around the blocks as submitted in the plans submitted by Principal Architect Design Plus shall kept clear of any obstruction for free movement of fire units in case of emergency.
9. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
10. Any flammable material for interior decoration shall strictly prohibited.




Principal

Bharatiya Vidya Bhawan's
Mehta Sadan